



COPY

STATE OF NEBRASKA

Pete Ricketts
Governor

NOV 7 2016

DEPARTMENT OF ENVIRONMENTAL QUALITY
Jim Macy

Director
Suite 400, The Atrium
1200 'N' Street
P.O. Box 98922
Lincoln, Nebraska 68509-8922
Phone (402) 471-2186
FAX (402) 471-2909
website: <http://deq.ne.gov>

Alan Doll
Dodge County Highway Department
435 North Park Street, Room 204
Fremont, NE 68025

COPY

RE: Operating Permit No. **15OWT025**
Onsite Wastewater Treatment System
2260 County Road 19, Fremont, NE 68025
NW ¼, NW ¼, Sec. 17, T17N, R08E, Dodge County

NDEQ ID: **106231**
Program ID: **15OWT025**

Agenda Item # 26a
Date 11-23-16

Dear Mr. Doll:

The Department has received the Notification of Construction Completion verifying that construction of the referenced onsite wastewater system has been completed in compliance with the approved plans and specifications and the system has been registered. Pursuant to Neb. Rev. Stat. Sec. §81-1506(2)(Reissue 1987), an operating permit for the system (enclosed) is hereby granted.

This Operating Permit is issued under the condition that the operation of the system be in compliance with NDEQ's Title 124 - Rules and Regulations for the Design, Operation and Maintenance of On-site Wastewater Treatment Systems.


Should ownership of the referenced Onsite Wastewater Treatment system change, NDEQ Title 124, Chapter 3, Section 007 provides that the transfer of ownership of a permitted system shall automatically authorize the new owner to operate under the existing permit. Subsequent permit holders are under the same obligations and conditions as the original permittee. The Department shall be notified of the transfer of ownership and given the name and address of the new owner.


If you have any questions please contact me at 402-471-8283 or mark.bauer@nebraska.gov.

Sincerely,

Mark Bauer, P.E.
Supervisor, Onsite Unit
Water Quality Division

cc: Sorin Juster, P.E.
Jean Andrews, Dodge County





Nebraska Department of Environmental Quality

Operating Permit No. 150WT0025

is hereby issued to

*Alan Doll for Dodge County Highway
Department*

For

*Based upon the notification of construction completion dated August 9, 2016 from Sorin Juster,
P.E. and the system registration (TS29098) submitted by Luke Kardell (C2496) for the*

*32 Gallon per Day and 150 Gallon per Day
Onsite Wastewater Treatment System*

Description:

*Holding tank system, consisting of a 3,000 gallon tank for the floor drains in the
shop building (150 gpd), and 1,500 gallon tank for the sanitary sewer waste (32
gpd). The holding tanks are to have a visible or audible alarm system or float that
indicates when the tanks are 90% full.*

located at

*2260 County Road 19, Fremont, NE
NW ¼, NW ¼, Sec. 17, T17N, R08E
Dodge County*

*Pursuant to a Delegation Memorandum dated August 22, 2016, and signed by the
Director, the undersigned hereby executes this document on behalf of the Director.*

Signed 11/7/16

Shelley Schneider

Shelley Schneider, Water Permits Division Administrator



20160067657